

1 **(April 3, 2006)**

2 **Submittals**

3 Section 5-05.3(1) is supplemented with the following:

4

5 Prior to beginning any concrete work, the Contractor shall submit a plan, for the
6 Engineer's review and approval, outlining the procedures to be used to prevent
7 high pH stormwater or dewatering water from entering surface waters. The plan
8 shall include how the pH of the water will be maintained between pH 6.5 and pH
9 8.5 prior to being discharged from the project or entering surface waters. The plan
10 shall conform to the requirements of Section 8-01.